

Project Name: Budapest One
Project ID: 38196



Quarterly Water Testing

The below schedule addresses the requirements of optimization Feature 35, part 1 in the WELL Building Standard v1 and for Innovation: v2 pilot [W01.3 c & W02.7 c]=W05

FEATURE 35: PERIODIC WATER QUALITY TESTING and for Innovation: v2 pilot [W01.3 c & W02.7 c]=W05
See measurable water parameters and frequency below.
See the required number of the sampling points in "Mintavételi pontok száma" spreadsheet

Budapest ONE Phase I.								
Dátum / Date	Mintavétel helye / Sampling point	Arzén / Arsenic [mg/L]	Higany / Mercury [mg/L]	Ólom / Lead [mg/L]	Réz / Copper [mg/L]	Zavarosság / Turbidity [NTU]	Összes kólibaktérium / Total coliforms	TESTING PERFORMED BY
Maximum határérték / Limit		0.01 mg/L.	0.002 mg/L.	0.01 mg/L	1.0 mg/L.	1.0 NTU.	0 CFU / not detected	
Frequency / Gyakoriság		quarterly / Negyedévente	quarterly / Negyedévente	quarterly / Negyedévente	quarterly / Negyedévente	quarterly / Negyedévente	Negyedévente / quarterly	
Mintavételi pontok száma és/ vagy helye	2+1							
YYYY/MM/DD								
2024.01.05	Tower B - Ground Floor Lobby - Restroom	-	-	-	-		0	Eurofins Analytical Services Hungary Kft.
	Tower B - Water dispenser - rooftop	0,0005	0,0002	0,0005	0,0005	0,25	0	
	Tower A - P1, FM Team kitchenette	0,0017	0,0002	0,0017	0,0774		0	
	Tower A - Well room	0,0024	0,0002	0,0105	0,0862		-	
2024.03.18	Tower A - Well room	0,0016	0,0002	0,0005	0,0098	-	-	Eurofins Analytical Services Hungary Kft.
	Tower B - Water dispenser - rooftop	0,0006	0,0002	0,0005	0,0005	1,7	0	
	Tower A - P1, FM Team - kitchenette	0,0018	0,0002	0,0017	0,0603	-	0	
	Tower A - P1, FM Team - changing room	-	-	-	-	-	0	
2024.06.10	Tower A - Well room	0,0018	0,0002	0,0005	0,0069	-	-	Eurofins Analytical Services Hungary Kft.
	Tower B - Water dispenser - rooftop	0,0006	0,0002	0,0005	0,0005	1,58	0	
	Tower A - P1, FM Team - kitchenette	0,0017	0,0002	0,0008	0,0357	-	-	
	Tower A - Ground Floor Lobby - Restroom	-	-	-	-	0,38	0	
	Tower B - Ground Floor Lobby - Restroom	-	-	-	-	0,25	0	
2024.09.05	Tower A - Ground Floor Lobby - Restroom	-	-	-	-	0,49	0	Eurofins Analytical Services Hungary Kft.
	Tower B - Water dispenser - rooftop	0,0009	0,0002	0,0005	0,0005	0,47	0	
	Tower B - Ground Floor Lobby - Restroom	-	-	-	-	0,43	0	
	Tower A - Well room	0,0015	0,0002	0,0005	0,0075	-	-	
	Tower A - P1, FM Team - kitchenette	0,0016	0,0002	0,0017	0,493	-	-	
2024.10.08	Tower B - Water dispenser - rooftop	-	-	-	-	0,37	-	Eurofins Analytical Services Hungary Kft.